DELUGE / PREACTION VALVE TRIPPING RECORD

Deluge and Preaction valves should be automatically tripped, cleaned and reset annually.
Do not apply grease or pipe compound on valve seats.

System No.	Date Tripped	Tested by	Air Pressure Before Test	Trip Method (SD, HD,PS)	Trip Point Air Pressure	Trip Time

HD = Heat Detectors, SD = Smoke Detectors, PS = Pull Station