DRY-PIPE VALVE TRIPPING RECORD

Dry-pipe valves should be tripped, cleaned and reset annually.
Do not apply grease or pipe compound on valve seats.

System No.	Date Tripped	Tested by	Water Pressure Before Test	Air Pressure Before Test	Trip Point Air Pressure	Time to Trip Valve	Time for Waterflow *

*It should take no more than 60 sec. for water to flow from an Inspectorôs Test Connection. If any system exceeds this maximum allowable time period, a quick-opening device or repairs may be needed.